

---

**From:** Michael A Glagola (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=MIC0210]  
**Sent:** 7/8/2015 11:50:22 AM  
**To:** Christine Harris (Generation - 34) [/O=DOMINION/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=Christ3]  
**Subject:** RE: Bremo and Possum Pt. Ash Pond Closing Water Management Overview

You are correct the GAI schedule shows Pond D dewatering to begin in October but based on what we have heard from DEQ this water will require a permit to discharge through 005 as well as treatment. But we can't submit the NPDES paperwork until it is decided what to do with Pond ABC water. I understand from Ken that Cathy is going to set up a meeting in the near future so that everyone is brought up to date with the situation.

Thanks,

Mike

**From:** Christine Harris (Generation - 34)  
**Sent:** Wednesday, July 08, 2015 11:05 AM  
**To:** Michael A Glagola (Generation - 34)  
**Subject:** Re: Bremo and Possum Pt. Ash Pond Closing Water Management Overview

Can you review the document? I think the date to start dewatering D is wrong

Thanks

Sent from my iPhone

On Jul 8, 2015, at 10:58 AM, Michael A Glagola (Generation - 34) <[michael.a.glagola@dom.com](mailto:michael.a.glagola@dom.com)> wrote:

Not the writing of the document but I did attend some of the meetings where some of these topics came up.

Mike

**From:** Christine Harris (Generation - 34)  
**Sent:** Wednesday, July 08, 2015 10:56 AM  
**To:** Michael A Glagola (Generation - 34)  
**Subject:** FW: Bremono and Possum Pt. Ash Pond Closing Water Management Overview

Hi

Did you have input into this? Thanks.

I see some inaccuracies.

Christine

**From:** Doug Wight (Generation - 34)  
**Sent:** Wednesday, July 08, 2015 10:32 AM  
**To:** Christine Harris (Generation - 34)  
**Subject:** FW: Bremono and Possum Pt. Ash Pond Closing Water Management Overview

Christine,

After our discussions yesterday, I softened the absolute option for the E Pond in the attached.

I discussed this attachment with Craymer and he mentioned that there should be less volume in ABC. I relayed our discussion yesterday, from last week with Glover, that 16Million Gallons, still isn't enough to be successful with moving water from ABC.

Trying to keep you informed,

Doug

**From:** Doug Wight (Generation - 34)

**Sent:** Wednesday, July 08, 2015 8:17 AM

**To:** David Craymer (Generation - 3)

**Cc:** John Smatlak (Generation - 6); Frank N Brayton (Generation - 34); Christine Harris (Generation - 34); Kenneth Roller (Services - 6); John Cima (Generation - 34); Michael J Winters (Generation - 34); Doug Wight (Generation - 34); Michael A Glagola (Generation - 34); William F Reed (Generation - 3); Jeffrey C Heffelman (Generation - 3)

**Subject:** Bremo and Possum Pt. Ash Pond Closing Water Management Overview

Dave,

The attached is per your request.

Thank you to Frank, Mike Winters, and Ken Roller for assistance.

Doug

Douglas L. Wight

Manager Dominion Power Gen BOP Engineering

Phone 804-273-3751 (8-730-3751)